

Army Public School
90, Alexandra Road,
Ambala Cantt

APS/2A

•📅 Sep 2024

**CALLING OF QUOTATION: PURCHASE OF ONLINE UPS 3 KVA ALONGWITH BATTERIES AND
STAND BY ARMY PUBLIC SCHOOL, AMBALA CANTT**

1. Please send sealed quotations for purchase of online UPS 3KVA alongwith batteries and stand by Army Public School, Ambala Cantt. Tender form alongwith technical specifications as per Annexure-I are enclosed herewith.
2. Quotations will be put in the quotation box kept in the school.
3. Rates once quoted in the quotation will be valid for minimum six months.
4. The quotation will be addressed to Principal, Army Public School, Ambala Cantt.
5. Last date of receipt of quotations is 17 Sep 2024 by 1300 hrs.



(Dr Paramjit Singh)
Principal

**TENDER FORM FOR PURCHASE OF 02 X COLOURED PHOTOCOPIER MACHINE FOR
MAIN WING OF ARMY PUBLIC SCHOOL, AMBALA CANTT**

1. Name of Firm/Contractor : _____
with full address, tele No & Email. _____
Tele No _____
Email No _____
2. GST No of the Firm/Contractor. : _____
3. PAN No of the Firm/Contractor : _____

4. **Details of items.**

Ser No	Details of item	Qty	Rate per item	GST %	Total Cost with GST
1.	Purchase of 02 x Coloured Photocopier Machine for Main Wing of Army Public School, Ambala Cantt as per detailed specification attached as Annex-I.	02			

5. Time for completion of the work / supply shall be 30 days from the date of issue of work / supply order.

6. Failure to complete the work / supply within the period of completion shall invite reduction of compensation at the rate of 0.2% of the contract amount per week till completion of work / job to the satisfaction of the school management. The school management may consider grant of extension of time beyond the initial period of completion in case he is fully satisfied that the delay is due to circumstance beyond control of the contractor.

7. No sub-letting of any part of portion of the work / supply shall be permitted and it shall be the sole responsibility of the firm / contractor undertaking the work / job to complete the work within time.

8. No advance payment shall be made.

9. The rates quoted by the contractor / vendor shall include all applicable taxes, octroi, tpt, loading/ unloading and labour charges and will be applicable for 90 days from the date of opening of tender.

10. Last date of receipt of sealed tenders duly completed is 1300 hrs on 17 Sep 2024. All bids received after 1300 hrs on 17 Sep 2024 shall be considered invalid and shall not be opened. Tenders will be opened on 18 Sep 2024 at 1100 Hrs.

11. This office reserves the right to cancel / accept / reject any / all tenders without assigning any reason for the same and decision of this institution will be final and binding.

12. **Note.** Successful bidder will provide the samples of items with their bids and will work as per specifications / approval given by the school to the vendor.

13. Commercial Bid Amount - Rs. _____
GST% - Rs. _____
Total - Rs. _____

Station : Ambala cantt

(Signature of Bidder with stamp
Accepting the above terms & conditions)

Date : Sep 2024

**INDICATIVE LIST OF LINE INTERACTIVE ONLINE UPS
WITH EXTERNAL BATTERIES (12V26AH)**

SNo	Item	Specification	Anticipated Quantity
1.	Line Interactive UPS 3KVA	Online UPS 3KVA Pure Sine-Wave Output Micro-Controller Based PWM Technology using MOSFET	02
2.	12V 26AH Battery	Sealed Maintenance Free (SMF) 12V 26AH Battery	08
3.	Batteries Stand (Rack)		01

QUALITATIVE REQUIREMENTS FOR PROCUREMENT OF MULTIFUNCTIONAL DEVICE

(PRINT/ COPY / SCAN)

SNo	Item	Technical Specification	Complied Yes / No	Deviation If any
1.	Capacity	3KVA		
2.	Input Voltage	100~300V AC (1Ph+N+PE)		
3.	Input Frequency (Hz)	45~65		
4.	Output Voltage	230±10% (1Ph+N+PE)		
5.	Output Frequency on Battery	50±1Hz		
6.	Waveform	Sine Wave		
7.	Transfer time (ms)	4-8 ms Typical		
8.	Load PF	0.6 (Standard)		
9.	Efficiency at Full Load	>90 %		
10.	Quality	ISO 9001, ISO 14001, ISO 45001, ISO 27001, BIS and RoHS		
11.	Safety	IEC/EN62040-1		
12.	Features	Low Battery, Overload, Fault conditions and Battery Mode, LED Indicator for AC Mode, Battery Backup Mode		
13.	Protection	Battery Low, Overload, Short Circuit, AC Input Low/ High & Fault conditions		
14.	Warranty	Min 2 years		
<u>BATTERY SPECIFICATION</u>				
15.	Battery Voltage	12 V		
16.	Capacity	26 Ah		
17.	Battery Type	Lead-Acid battery with suspended electrolyte : Leak-proof		
18.	Material	Container & Lid: ABS		
19.	Output Frequency	47 – 63 Hz		
20.	Operating Environment	0 – 40 deg C		
21.	Relative Humidity	Operating Relative Humidity: 0-95% Storage Relative Humidity: 0-95%		
22.	Warranty	Min 2 years		
23.	Stand (Rack) for Batteries	Battery Rack for 08 Nos. 12 V-26AH Batteries		

PROFORMA FOR SUBMISSION OF FINANCIAL BID

SNo	Item	Make & Model	Basic rate for each quantity (in Rs)	Taxes / GST (in Rs)	Net Amount inclusive of taxes (In Rs)
1.	Line Interactive UPS 3KVA				
2.	12V 26AH Battery				
3.	Batteries Stand				

****Note: the quantities may change according to the requirements of the Institute****

(Signature of authorized signatory)

Name & Address of Firm .

Authorised Signature & Seal of the Firm

Place:

Date: